

## STATE OF MAINE DEPARTMENT OF TRANSPORTATION 16 STATE HOUSE STATION AUGUSTA, MAINE 04333-0016

DAVID A. COLE

November 16, 2009 Subject: **Verona** 

Federal Project No: NH-007965.58D

State Pin No: 007965.58 D

Amendment No. 1

Dear Sir/Ms:

The following questions have been received:

**Question:** There is a concrete slab adjacent to the building approximately 80' x 100' with a possible frostwall. Does this slab and frostwall get removed as part of this bid?

**Response:** The building foundation is to be left intact for potential future use. The surface of the slab foundation shall be left in its bare, exposed condition and adequate precautions should be taken to avoid damaging the foundation during the demolition of the building and any associated demolition acts. It shall be noted that there is a concrete slab on site that is covered by a steel beam(s), the removal of this steel and concrete slab is **NOT** included in the scope of work for this contract.

Question: Is the existing pavement to be removed as part of this contract.

**Response:** All existing paving shall be left in place and undisturbed to the greatest extent possible.

Question: What is the scope of work for removing the electrical source?

**Response:** All wires are to be removed from the building to the first service pole. All service poles and all remaining wires are to remain in place and undisturbed.

**Question:** Is the disposal of paints, aerosols, cleaners, etc. included as part of this contract?

**Response:** The Department is responsible for the disposal of the paints, aerosols and cleaners.

Question: Is the removal of any heating fuel included as part of this contract?



**Response:** The Department is responsible for the removal and disposal of all heating fuel.

Question: Is the DBE Verification form required to be submitted for this project.

Response: Yes

Consider this information prior to submitting your bid on November 18, 2009.

Sincerely,

Scott Bickford

Contracts & Specifications Engineer